

## GRUPOS CONTRAINCENDIOS

Modelo <i>Model</i> <i>Modèle</i>	Bomba Principal <i>Main Pump</i> <i>Pompe Principale</i>	Bomba Jockey <i>Jockey Pump</i> <i>Pompe Jockey</i>	Tensión <i>Voltage</i> 3~ 50Hz	Caudal Nominal <i>Nominal F. / D. Nominal</i>		Caudal sobrecarga <i>Overload F. / D. Surcharge</i>	
				Q (l/h)	H (m)	Q (l/h)	H (m)
<b>UNE EJ 12/50</b>	4 HP	1,5 HP	400 V + N	12000	50	16800	35
<b>UNE EJ 12/60</b>	5,5 HP	1,5 HP	400 V + N	12000	60	16800	42